



# CERTIFICATE OF VALIDATION

**Certification Number:** 1184C

**Authorization Date:** December 16, 2021

**Expiration Date:** December 16, 2026

**COMPANY:** Alpine Overhead Doors

**MANUFACTURING LOCATION(S):** 8 Hulse Road East Setauket, NY 11733

**PRODUCT NAME:** FEMA-TITE Steel Roll-up Door System

**STANDARD(S) VALIDATED:** ICC 500-2020; FEMA P361-2021

**ADDITIONAL INFORMATION:** Series/Model = FEMA-TITE  
Design Pressure = 254 psf/Test Pressure = 305 psf  
Missile Impact = 13ft/15lb 2X4 @ 100 mph  
Maximum Tested Size = 20ft width X 20ft height  
Minimum Tested Size = 3ft 6in width X 4ft height  
Minimum 16 gauge Galvanized or Stainless Steel

Only products bearing the PRI-CMT Validation Program for Building Materials Seal have been certified in accordance with the standard listed above. Please reference <https://www.pri-group.com/services/validation-certification> for a complete and current list of products in good standing in the PRI-CMT Validation Program for Building Materials certification program.

Decision By:

Brad Grzybowski  
Managing Director

Issued By:

Brian Wilson  
Program Manager